

Panasonic Fire & Security Europe AB Jungmansgatan 12 SE-211 11 Malmö, Sweden Tel +46 (0)40 697 70 00

DECLARATION OF PERFORMANCE

According to Construction Products Regulation (EU) No 305/2011 Document No. <u>ESN-FP0302-03</u>

1. Unique identification code of the product-type:

Type 4439 Enclosed Addressable manual call point with isolator

2. Intended use/es:

Fire detection and fire alarm systems installed in and around buildings

3. Manufacturer:

Panasonic Fire & Security Europe AB Jungmansgatan 12, SE-211 11 Malmö, Sweden Tel: +46 (0)40 697 70 00 https://www.panasonic-fire-security.com/

4. Authorized representative:

Niels Erdmann Panasonic Testing Centre Panasonic Marketing Europe GmbH Winsbergring 15, 22525 Hamburg, Germany

5. System/s of AVCP:

System 1

6a. Harmonised standard:

EN 54-11:2001 + A1:2005

EN54-17:2005 + AC:2007

Notified body/ies::

VdS Schadenverhütung GmbH

Accreditation No. 0786

6b. European Assessment Document:

Not applicable

Technical Assessment Body:

Not applicable

Notified body/ies:

Not applicable



7. Declared performance/s:

Essential characteristics	Performance	Harmonized technical specification		
		EN54-11:2001 + A1:2005	EN54-17:2005 + AC:2007	
Nominal activation conditions / Sensitivity and Performance under fire conditions	Passed	4.3.2, 4.4, 4.7.1, 4.7.4, 5.2, 5.3	n/a	
Performance under fire conditions	Passed	n/a	5.2	
Operational reliability	Passed	4.2, 4.3.1, 4.5, 4.6, 4.7.2, 4.7.3, 4.7.5, 4.8, 5.4, 5.5	4	
Durability of operational reliability: temperature resistance	Passed	5.7, 5.8, 5.9	5.4, 5.5	
Durability of operational reliability: vibration resistance	Passed	5.14 to 5.17	5.9 to 5.12	
Durability of operational reliability: humidity resistance	Passed	5.10, 5.11, 5.12, 5.19	5.6, 5.7	
Durability of operational reliability: corrosion resistance	Passed	5.11, 5.13	5.8	
Durability of operational reliability:	Passed	5.6, 5.18	5.3, 5.13	

8. Appropriate Technical Documentation and/or Specific Technical Documentation:
Not applicable

Signed for	and	on	behalf	of the	manufacturer	by
		<		1		

(Signature): Rutger Pålsson
(Title): Technical Director

Place and date of issue

May 6, 2019

Authorized Representative in EU:
(Date): 0 8, Mai 2019
(Signature): (Printed Name): Niels Erdmann
Panasonic Testing Centre

Winsbergring 15, 22525 Hamburg, Germany

Panasonic Marketing Europe GmbH