

Panasonic Fire & Security Europe AB Jungmansgatan 12 SE-211 11 Malmö, Sweden Tel +46 (0)40 697 70 00

DECLARATION OF PERFORMANCE

According to Construction Products Regulation (EU) No 305/2011

Document No. <u>ESN-FP0310-02</u>

1. Unique identification code of the product-type:

Type 4480 Addressable wall VAD with isolator

2. Intended use/es:

Fire detection and fire alarm systems installed in and around buildings

3. Manufacturer:

Panasonic Fire & Security Europe AB Jungmansgatan 12, SE-211 11 Malmö, Sweden Tel: +46 (0)40 697 70 00 https://www.panasonic-fire-security.com/

4. Authorized representative:

Niels Erdmann Panasonic Testing Centre Panasonic Marketing Europe GmbH Winsbergring 15, 22525 Hamburg, Germany

5. System/s of AVCP:

System 1

6a. Harmonised standard:

EN54-23:2010

EN54-17:2005 + AC:2007

Notified body/ies::

VdS Schadenverhütung GmbH

Accreditation No. 0786

6b. European Assessment Document:

Not applicable

Technical Assessment Body:

Not applicable

Notified body/ies:

Not applicable



7. Declared performance/s:

Essential characteristics	Performance	Harmonized technical specification	
		EN54-23:2010	EN54-17:2005 + AC:2007
Performance under fire conditions	Passed	4.3.1 to 4.3.7	5.2
Operational reliability	Passed	4.2.1 to 4.2.8	4
Durability of operational reliability: temperature resistance	Passed	4.4.1.1 to 4.4.1.3	5.4, 5.5
Durability of operational reliability: vibration resistance	Passed	4.4.3.1 to 4.4.3.4	5.9 to 5.12
Durability of operational reliability: humidity resistance	Passed	4.4.2.1 to 4.4.2.3	5.6, 5.7
Durability of operational reliability: corrosion resistance	Passed	4.4.4	5.8
Durability of operational reliability: electrical stability	Passed	4.4.5	5.3, 5.13

8. Appropriate Technical Documentation and/or Specific Technical Documentation:
Not applicable

Signed for and on behalf of the manufacture	r by:
---	-------

(Signature):
(Printed name): Rutger Pålsson
(Title): Technical Director

Place and date of issue

May 6, 2019

Authorized Representative in EU: (Date): 0 8. Mai 2019	
(Date): U 8, Mai 2019	
(Signature): [N. GC	190
(Printed Name): Niels Erdmann	
Panasonic Testing Centre	
Panasonic Marketing Europe GmbH	

Winsbergring 15, 22525 Hamburg, Germany