

Panasonic Fire & Security Europe AB Jungmansgatan 12 SE-211 11 Malmö, Sweden Tel +46 (0)40 697 70 00

DECLARATION OF PERFORMANCE

According to Construction Products Regulation (EU) No 305/2011

Document No. <u>ESN-FP0319-01</u>

1. Unique identification code of the product-type:

Type 4614 Wireless manual call point

2. Intended use/es:

Fire detection and fire alarm systems installed in and around buildings

3. Manufacturer:

Panasonic Fire & Security Europe AB Jungmansgatan 12, SE-211 11 Malmö, Sweden Tel: +46 (0)40 697 70 00 https://www.panasonic-fire-security.com/

4. Authorized representative:

Niels Erdmann Panasonic Testing Centre Panasonic Marketing Europe GmbH Winsbergring 15, 22525 Hamburg, Germany

5. System/s of AVCP:

System 1

6a. Harmonised standard:

EN 54-11:2001 + A1:2005

EN 54-25:2008 + AC:2012

Notified body/ies::

VdS Schadenverhütung GmbH

Accreditation No. 0786

6b. European Assessment Document:

Not applicable

Technical Assessment Body:

Not applicable

Notified body/ies::

Not applicable



7. Declared performance/s:

Essential characteristics	Performance	Harmonized technical specification		
		EN54-11:2001 + A1:2005	EN54-25:2008 + AC:2012	
Nominal activation conditions / Sensitivity and Performance under fire conditions	Passed	4.3.2, 4.4, 4.7.1, 5.2, 5.3	n/a	
Performance parameters under fire conditions	Passed	n/a	4.1, 4.2.2, 5.2, 8.3.7	
Response delay (response time to fire)	Passed	n/a	8.2.3, 8.2.6	
Operational reliability	Passed	4.2, 4.3.1, 4.5, 4.6, 4.7.2, 4.7.3, 4.7.5, 4.8, 5.4, 5.5	4.2.1, 4.2.3, to 4.2.7, 5.3, 5.4, 6, 7, 8.2.2, 8.2.4, 8.2.5, 8.2,7, 8.2.8, 8.2.9, 8.3.1, 8.3.2, 8.3.3, 8.3.4, 8.3.5, 8.3.6	
Durability of operational reliability: temperature resistance	Passed	5.7, 5.9	8.3.9 to 8.3.11	
Durability of operational reliability: vibration resistance	Passed	5.14 to 5.17	8.3.16, to 8.3.19	
Durability of operational reliability: humidity resistance	Passed	5.10, 5.12	8.3.12, 8.3.14	
Durability of operational reliability: corrosion resistance	Passed	5.13	8.3.15	
Durability of operational reliability: electrical stability	Passed	5.6, 5.18	8.3.20	

8. Appropriate Technical Documentation and/or Specific Technical Documentation:

Not applicable



Signed	for or	ad on	hohol	f of the	monufo	adarman l	
DIEHER	IOL ST	EU VII	Delian	l ui me	manuts	ichirer i	W

(Signature):

(Printed name): Rutger Pålsson

(Title): Technical Director

Place and date of issue March 14, 2019

Authorized Representative in EU:

(Date): 1,5. März 2019 (Signature):

(Printed Name): Wolfram Kühl
Panasonic Testing Centre

Panasonic Marketing Europe GmbH

Winsbergring 15, 22525 Hamburg, Germany